



Conference Room

GLPAC



IECC 2015 Code Compliance:

- ▶ Manual Controls (C405.2.1.1.3)
- ▶ Manual On/Partial On (Vacancy Sensing Mode) (C405.2.1.1.2)
- ▶ Time-switch Controls (Programmable timeclock) (C405.2.2)
- ▶ Bi-level Control (0-10V Dimming) (C405.2.3.1.4)



Symbol	Product	Qty.	Description
	GLPAC-DIMFLV4	1	Green Light Integrated Lighting System, 4-Channel
	GLS-ODT-C-NS	1	Dual-Technology Ceiling Mount Occupancy Sensor
	C2N-CBD-P	1	Cameo® Keypad, Standard Mount