



Huddle Space / Break Room

GLPP



IECC 2015 Code Compliance:

- ▶ Manual Controls (C405.2.1.1.3)
- ▶ Manual On/Partial On (Vacancy Sensing Mode) (C405.2.1.1.2)
- ▶ Automatic Full Off (C405.2.1.1.1)
- ▶ Bi-level Control (0-10V Dimming) (C405.2.3.1.4)



Product	Product	Qty.	Description
	GLPP-DIMFLVCN-PM	1	1-Ch 0-10V Dimmer with Cresnet
	GLS-ODT-C-NS	1	Dual-Technology Ceiling Mount Occupancy Sensor
	GLPPA-KP	1	In-Wall Keypad for GLPP